

CREATIV Industry Energy Efficiency

Workpackage: D4.11: Concept, Calculation and 3D Design of R744 Oil Free Turbo Compressor Unit

Date: 24.09.2010



Efficient heating and cooling (SP4)



Content: page 1. Task and Background 3 2. Target Conditions and Specification 4 3. Design and Calculation of Turbo Compression Unit 5 3.1 Pre – Calculation – Turbo-Quick-Dim Tool 3.2 One–Dimensional Turbo Simulation Tool 3.3 Naming and declaration of compressor components 3.4 Number of Stages / Speed Range 3.5 1-D-Simulation Results 3.6 R744 Turbo Compressor Operation Map 3.7 R744 2-Stage Turbo Sealing Loss Model 3.8 Open / Closed type wheel comparison 3.09 CFD Results 3.10 Influence of shaft diameter 18 4. Turbo Unit Design – 3D 5. Rotor Dynamics – First Calculation 19 6. Summary / Conclusions 21

Project-No:	9022.000
Customer:	CREATIV
Creator:	DiplIng. C. Schmälzle
Date:	11.11.2010
Status:	Index b



1. Task and Background

Today's refrigeration systems have to use a defined portion of oil in order to provide lubrication of mechanical moving parts in the compressors. This oil is mainly added into the compressor but is transported with the working media into the system, so a not negligible amount is pumped around in the system. An oil free compressor (and with that oil free system) would therefore have following major advantages:

- improved heat transfer in the heat exchangers
- improved system efficiency \rightarrow energy saving
- reduction of heat exchanger size
- lower system complexity (no oil return)
- increase of temperature range (today oil is limiting)
- reduction of servicing and maintenance effort

In combination with natural refrigerants an oil free refrigeration system would offer a significant step forward towards cost saving, fuel saving and environmentally friendly refrigeration systems.

In previous studies R744 (carbon dioxide) was found as a very promising solution for such a oil free turbo machine among the natural refrigerants.

Task of this study is a 3D design, calculation and definition of R744 turbo compressor unit under given specifications for a defined application in order to pre-determine required amount of stages, required dimensions and to get a first prediction of possible, reachable compressor efficiencies.



2. Target Conditions and Specifications

	ood
--	-----

Media: R744 (carbon dioxide) oil free

Inlet Conditions: 30bar, 0°C (5K SH)

Outlet Conditions: 55 to 80 bar, best efficiency at 65 bar

Mass Flow: 6000 kg/h, +/- 5% in application

Power In: approx. 75 kW

- Speed range: approx. 50.000 rpm
- Efficiency Target: > 75% (turbo stages only)







3. Calculation and 3D Design of R744 Turbo Compressor Unit

3.1 Pre – Calculation: Turbo-Quick-Dim Tool

In a first step a simplified excel-calculation tool is created ("Turbo-Quick-Dim"), allowing a first prediction of required stages, a fist idea of outer diameter and speed range of compression stages:

This calculation tool is based on procedure as mentioned in handbook of mechanical engineering: Dubbel-Version18-R73-Capter7.5.

1. System and Overall Inputs

Inlet pressure	p1	30,0 [bar]	Input
Corresponding evaporating temperature	t_evap	-5,4 [°C]	Calculated
Required overheat	dt	5 [K]	Input
Inlet temperature	t1	-0,4 [°C]	Calculated
Outlet pressure	p2	65 [bar]	Input
Max. allowable speed of rotation	n_max	45000 [1/min]	Input
		750 [1/s]	Calculated
Required mass flow	m_dot	6000 [kg/h]	Input
		1,67 [kg/s]	Calculated
Assumed overall compressor efficiency	eta_overall	75 [%]	Input

Step 1: Definition of running conditions, especially inlet temperature and pressure, outlet pressure, available electrical driving power, available max. motor speed, required refrigerant mass flow.

2. Gas Data Calculations

Inlet density	roh_1	77,7 [kg/m³]	Calculated
Inlet enthalpy	h_1	-65,4 [kJ/kg]	Calculated
Inlet entropy	s_1	-0,835 [kJ/kg]	Calculated
Inlet speed of sound	a_1	221 [m/s]	Calculated
Inlet volume flow	V_dot_1	0,021 [m³/s]	Calculated
Isentropic outlet temperature	t_2_is	58 [℃]	Calculated
Isentropic outlet enthalpy	h_2_is	-32,9 [kJ/kg]	Calculated
Isentropic delta h	dh_is	32,4 [kJ/kg]	Calculated
Real delta h - eta_overall considered	dh_real	43,2 [kJ/kg]	Calculated
Outlet enthalpy	h_2	-22,1 [kJ/kg]	Calculated
Outlet temperature	t_2	65 [℃]	Calculated
Outlet density	roh_2	135 [kg/m³]	Calculated
Outlet speed of sound	a_2	250 [m/s]	Calculated

Step 2: Calculation of real gas values out of given in and outlet conditions. For the calculation of the real outlet temperature t_2 an assumed, reachable compressor efficiency is used. The real gas calculation is based on R744 data base of Prof. Wagner, Univ. of Essen, Germany.



X	70,0 [%]	Input value
u2_max	160 [m/s]	Calculated
psi_target	1,1 [-]	Input value
phi	0,023 [-]	Calculated
d2	97,6 [mm]	Calculated
у_р	22,0 [kJ/kg]	Calculated
i	2,5 [-]	Calculated
	x u2_max psi_target phi d2 y_p i	x 70,0 [%] u2_max 160 [m/s] psi_target 1,1 [-] phi 0,023 [-] d2 97,6 [mm] y_p 22,0 [kJ/kg] i 2,5 [-]

Step 3: Determination of stages required. Important input value is the speed of sound approach, which determines the approach of the outer wheel velocity towards the speed of sound of the gas. Literature is showing 40 to 90%, 90% as maximum. The lower the speed of sound approach, the more stages are required.

More stages does also mean more possible leakages and complexity of the real turbo machine, so our target here was to minimise the required amount of stages.

Basic result: for the given conditions a stage amount of 2 for the R744 turbo is calculated and the blade outer diameter is below 100 mm.

4. Further output values

Compressor power consumption	P_clutch	72,07 [kW]	Calculated
	w_shan	15,29 [1011]	Calculated
Flow-through coefficient	phi sigma	0,023 [-] 0,128 [-]	Calculated
Diameter coefficient	delta	7,0 [-]	Calculated

Step 4: Important for layout of the turbo e-motor is the power consumption and driving torque required at the calculated condition. This calculation is based on the estimated overall efficiency.

Basic result: E-drive running at 45.000 rpm requires 15,3 Nm driving torque at this point, resulting in total 72 kW output shaft power.



5. Pressure distribution of stages and geometry aspects

	,	 		
Chosen amount of stages		i_set	2,00 [-]	Rounded value
Pressure ratio per stage		pi_stage	1,47 [-]	Calculated
Medium inlet velocity		c_m	50,0 [m/s]	Input value
Inlet diamter (out of design aspec	cts)	d_1	40,0 [mm]	Input value

A common medium inlet velocity can be found in literature from 30 to 100 m/sec. Inlet diameter is depending on the real compressor design and alignment, shaft and bearing concept.

	p_out [bar]	roh [kg/m³]	V_dot [m³/s]	A_required [mm ²]	b	_1 [mm]	delta p [bar]
Stage 1	44,1	106,2	0,01569	523,0		7,5	14,2
Stage 2	65,0	134,7	0,01237	412,5		6,4	20,8



Step 5: With a main input of the given stages (rounded value to full number), the expected pressure distribution is calculated moreover the width b2 (see sketch above) is determined. Main result: Pressure distribution 30 - 44 - 65 bar. Stage 1 width is 7,5 mm, Stage 2 width is 6,4 mm.

Conclusion of Quick-Dim calculation: a very compact R744 turbo compressor with 100 mm outer diameter, 2 stages and narrow width of 7,5 and 6,4 mm is pre calculated.



3.2 One–Dimensional Turbo Simulation Tool

Within in this study a common simulation tool for turbo compressors was chosen for the 1D study. A 1D study gives a very good first result on the real compressor dimensions required and efficiency prediction.

These simulation tools allow the design, changing of parameters, input of sealing concepts and prediction of expected efficiencies. The targeted main outputs are

- number of stages
- main dimensions
- impeller type open or closed
- amount of blades
- diffuser concepts
- efficiency prediction incl. leakage models

3.3 Naming and declaration of compressor components



Project-No:	9022.000
Customer:	CREATIV
Creator:	DiplIng. C. Schmälzle
Date:	11.11.2010
Status:	Index b



3.4 Number of Stages / Speed Range



Chart above is showing variation on amount of stages and also a speed variation. Basic results are

- a one stage solution can not meet efficiency target
- a three stage solution has theoretically an advantage towards 2-stage, but in real world rotor dynamic effects and increased leakage surfaces must be considered
- therefore a 2-stage solution is best compromise for given conditions in order to meet the 75% efficiency target, whereby
- the increase of speed (and with that increase of power in and mass flow) would offer further efficiency potential, see green box 2-stages at 75krpm

Project-No:	9022.000
Customer:	CREATIV
Creator:	DiplIng. C. Schmälzle
Date:	11.11.2010
Status:	Index b



3.5 First 1-D-Simulation Results

Parameter	Units	Stage 1	Stage 2	Overall	
Mass Flow Rate	Kg/s	1.667	1.66622	1.667	efficiency goal of
Shaft Speed	rpm	45000	45000	45000	> 75% is
Stage Power	kW	38.9	33.3	72.2	
Stage PR _{TT}	-	1.55	1.40	2.17	achievable
Stage PR _{TS}	-	1.51	1.39	2.10	
Stage ηπ	-	76.30%	76.79%	76.53%	*
Stage η _{TS}	-	71.56%	74.61%	72.97%	
Rotor η_{TT}	-	88.46%	88.18%	88.33%	
Exit Pressure	bar			65.11	
]

The first 1-D simulation results confirm the results of the Quick-Dim simulation tool with two stages. The outer blade diameter is even smaller than calculated in quick. The goal of achieving > 75% is achievable.

Project-No: Customer: Creator: Dipl. Date: Status:	9022.000 CREATIV -Ing. C. Schmälzle 11.11.2010 Index b	CREATIV Industry Energy Efficiency	
Version: 1.2 (08.	10.2004)		Page 11 of 21

First 1-D simulation results dimensions:



A 75kW R744 turbo stage unit with two stages can be designed very compact. The blade outer diameter is below 100 mm the total axial length is below 150 mm.

Project-No:9022.000Customer:CREATIVCreator:DiplIng. C. SchmälzleDate:11.11.2010Status:Index b	CREATIV Industry Energy Efficiency	
Version: 1.2 (08.10.2004)		Page 12 of 21

3.6 R744 Turbo Compressor Operation Map



Results efficiency map: The target output pressure p2 from 55 to 80 bar is reached with a speed variation from 40 to 50 krpm. Below 55 bar outlet pressure the efficiency drops significantly.



Project-No:902Customer:CRECreator:DiplIng. C. SchrDate:11.11Status:Ir	22.000 EATIV mälzle 1.2010 Industry Energy Efficiency	
Version: 1.2 (08.10.2004)		Page 13 of 21

3.7 R744 2-Stage Turbo Sealing Loss Model



For the sealing loss model realistic, achievable values are assumed.

Project-No:	9022.000
Customer:	CREATIV
Creator:	DiplIng. C. Schmälzle
Date:	11.11.2010
Status:	Index b



3.8 Open / Closed type wheel comparison



A covered wheel has internal advantages for flow guidance, but additional front side leakage losses. The open type wheel on the other hand has higher passage losses. This results in total in comparable total efficiencies of these two types. But a closed type wheel offers following advantages

- stiff and rigid blade design, reduced critical frequencies
- reduced axial bearing forces (see below)

Project-No:	9022.000
Customer:	CREATIV
Creator:	DiplIng. C. Schmälzle
Date:	11.11.2010
Status:	Index b

CREATIV Industry Energy Efficiency



Version: 1.2 (08.10.2004)

			Covered Impellers				Open Impellers		ers
	Parameter	Units	Stage 1	Stage 2	Overall		Stage 1	Stage 2	Overall
	Mass Flow Rate	Kg/s	1.667	1.62759	1.667		1.667	1.62753	1.667
	Shaft Speed	rpm	45000	45000	45000		45000	45000	45000
ЭĊ	Stage Power	kW	39.7	33.1	72.8		39.0	32.2	71.3
nar	Stage PR _∏	-	1.56	1.41	2.19		1.55	1.40	2.17
orn	Stage PR _{TS}	-	1.52	1.40	2.12		1.51	1.39	2.10
erf	Stage _∏	-	75.68%	76.93%	76.25%		75.98%	77.78%	76.79%
α.	Stage _{TS}	-	71.12%	74.79%			71.33%	75.59%	
	Exit Pressure	bar			65.81				65.17
	Axial Thrust	N	-167.9	-704.4	-872.4	\mathbf{h}	-1512.7	-1874.8	-3387.5
						ノ			

Calculation above shows significant reduction of axial thrust forces with closed impeller type. Hence the axial bearing solution for the R744 turbo unit is judged as critical, this significant reduction and the closed wheel type has to be taken into consideration.

Project-No:	9022.000
Customer:	CREATIV
Creator:	DiplIng. C. Schmälzle
Date:	11.11.2010
Status:	Index b



3.09 First CFD results



First CFD with ideal gas values shows good results, not perfect yet. The dark blue area in the return channel with zero flow velocity (dead area) has to be reduced.

Project-No:	9022.000
Customer:	CREATIV
Creator:	DiplIng. C. Schmälzle
Date:	11.11.2010
Status:	Index b



3.10 Influence of shaft diameter



In this study and calculation a shaft radius of 10 mm was chosen, as best compromise of stiffness and efficiency loss. Further, detailed rotor dynamic calculations must confirm and verify this assumption.

Project-No:	9022.000
Customer:	CREATIV
Creator:	DiplIng. C. Schmälzle
Date:	11.11.2010
Status:	Index b



4. Turbo Unit Design – 3D



With given simulation results a 3D model of a possible R744 turbo unit, 2-stages was designed. Detailed solutions on sealing and manufacturer feedback required in next steps to further optimise design. After that housing solutions and shaft bearing solutions must follow.

Project-No:	9022.000
Customer:	CREATIV
Creator:	DiplIng. C. Schmälzle
Date:	11.11.2010
Status:	Index b



5. Rotor Dynamics – First Calculation



Model assumptions:

- standard ball bearings with a bearing stiffness of 20 kN/mm
- closed impellers
- aluminium alloy for impellers
- standard motor geometry chosen
- both impellers overhung on one shaft end





Results:

- first undamped critical speed predicted to occur at 35.000 rpm
- second undamped critical speed > 100.000 rpm
- with a shaft diameter of 14 mm below the 2nd stage impeller, the localised shaft bending is in acceptable limits
- design speed is above the 1st critical speed \rightarrow damping required

Project-No:	9022.000
Customer:	CREATIV
Creator:	DiplIng. C. Schmälzle
Date:	11.11.2010
Status:	Index b
Version: 1.2	2 (08.10.2004)



6. Summary / Conclusions

With the given conditions of the application a R744 oil free turbo compressor unit was calculated and a 3D design of the stages, diffusers, return channels was generated. A two stage compressor is the best compromise for the given condition, the focus for the detailed design must be on leakage reduction. A possible technology is shown. The target of >75% of the compressor unit only (without e-motor or bearing friction losses) are achievable. The high density of the R744 results in a very compact design. First CFD and rotor dynamic results are presented, but both have to be detailed in next design and development round, when housing, bearing and further compressor parts will be determined. Expected dimensions around 105 mm blade outer diameter and below 130mm total axial length.

